



- 94 No person may tap into any fire hydrant for any purpose other than fire suppression or emergency aid, without first obtaining written approval from the water purveyor supplying water to the hydrant and from the Monterey County Health Department (per Section 6[L], ORD. 3522).
- 95 All hoses used in conjunction with any construction on site shall be equipped with a shutoff nozzle. When an automatic shutoff nozzle can be purchased or otherwise obtained for the size of type of hose in use, the nozzle shall be an automatic shutoff nozzle (per Section 6[K], ORD. 3522).
- 96 No potable water may be used for compaction or dust control purposes in construction activities where there is a reasonably available source of reclaimed or other sub-potable water approved by the Monterey County Health Department and appropriate for such use (per Section 6[K] ORD. 3522).
- 97 The use of solders containing more than two-tenths of 1 percent lead in making joints on private or public water supply systems is prohibited (per SB 164).

SLEEPY HOLLOW STEELHEAD REARING FACILITY

SCALE: 1" = 30 ft
DATE: 11/21/94

APPROVED BY:

DRAWN BY DHDettman

REVISED

MONTEREY PENINSULA WATER MANAGEMENT DISTRICT

ROUTING -- WATER, AIR, & DRAIN LINES

DRAWING NUMBER
12