



79

All toilets shall be ultra low-flow toilets with a maximum tank size or flush capacity of 1-1/2 gallons, all shower heads shall have a maximum flow capacity of 2-1/2 gallons per minute, and all hot water facets and hot water heater serving such facets shall be equipped with a hot water recirculating system (per Section 6(Q), ORD 3522).

SLEEPY HOLLOW STEELHEAD REARING FACILITY

Scale: 1/4"=1ft

Date: 5/10/94

Drawn By: DDettman

MONTEREY PENINSULA WATER MANAGEMENT DISTRICT

OFFICE/LAB--FLOOR PLAN & ELEVATIONS

Drawing Number

4