

2013 Water Efficiency Requirements

*ALL non-residential water users must install:**

- High efficiency toilets (1.28 gallons per flush (gpf)) unless already ultra low flush (1.6 gpf)
- High efficiency urinals (0.5 gpf)
- Showerheads: 2.0 gallons per minute (gpm)
- Public Washbasins: 0.5 gpm or 0.25 gpm for automatic shutoff
- Private washbasins (e.g., hotel or motel guest rooms and hospital patient rooms): 1.5 gpm max.
- All other sinks: 2.2 gpm max.
- High efficiency clothes washers (water factor <5.0)
- Water efficient ice machines
- Water efficient pre-rinse spray valves (1.6 gpm)
- Placards or decals promoting water conservation in restrooms, kitchens and dining areas
- Drinking water (tap) provided only upon request. Notification is required at each table or on the menu
- Towel and linen reuse programs
- Car washes must recycle 50% of water used

*As applicable



www.montereywaterinfo.org



**BY DECEMBER 31, 2013,
EXISTING NON-RESIDENTIAL
WATER USERS MUST IMPLEMENT
WATER EFFICIENCY MEASURES**

Details and additional information about rebates and other
programs can be found online at www.montereywaterinfo.org
or call the Water Management District at 831-658-5601



5 Harris Court, Building G, Monterey, California 93940

P: 831.658.5601 F: 831.644.9538

www.montereywaterinfo.org

PRSR STANDARD
U.S. POSTAGE
PAID
ALL AMERICAN
MAILING